

To: Boothbay Planning Board  
From: Mark Eyerman  
Subject: Revised Section 9  
Date: November 25, 2019

Attached is an updated version of Section 9 Environmental Performance Standards. This includes the changes discussed at the last meeting. Here is an overview of the changes:

1. I moved what had been 9.3.3 to the beginning of the stormwater section and made it 9.3.1
2. I increased the thresholds for a drainage plan to 4,000 SF of disturbed area and 2,000 SF of impervious area
3. I increased the thresholds for a stormwater management plan to 10,000 SF of impervious area except when the average slope is greater than 15% then the threshold stays at 5,000 SF as in the earlier version.
4. I edited the LID provisions to make it clear that they apply only when a stormwater management plan is required.